Scott. II-48—23,202—6-2-23.

Public Works (1926)' Department

p.29.16

Misc SERIES.

Go1457

G.O. No. 5771

5771

DATED 2-4-1926.

M

[**Despatch Abstract.**]

Electricity – The Bellary Electric Licence 1926 – Conditions, rates, etc for the supply of electrical energy – Approved

TELEPHONE No.

TELEGRAMS.
"BESCO."

PLEASE QUOTE THIS OFFICE LETTER No. IN ALL YOUR COMMUNICATIONS.

THE BELLARY ELECTRIC SUPPLY Co., Ltd.,

S. M. HUSSAIN,
Managing Director.

BELLARY,

Ref. No. 53/4.

17th February '25.

M.R. Kharegat, Esqr., Assoc. M. Inst. C.E.,
Offg. Secretary to the Government,
of Madras, Chepauk, Madras.

Dear Sir,

We enclose herewith 3 book-lets of conditions, rates and general information for the Supply of Electric Energy together with a copy signed by Mr. E.J.B. Greenwood for sanction under Sec. 21 of the Act.

Trusting to be favoued with your sanction for distributing them to our consumers.

Yours faithfully,
The Bellary Electric Supply Co., Ltd.,

Managing Director

[illegible]
[illegible]
19/2

C.No. 1212 A.I.
31-3-25

TELEPHONE No.

TELEGRAMS.
"BESCO"

PLEASE QUOTE THIS OFFICE LETTER No. IN ALL YOUR COMMUNICATIONS

THE BELLARY ELECTRIC SUPPLY Co., Ltd.,

S. M. HUSSAIN,
Managing Director.

BELLARY,
30th March 1925.

Ref No. 53/5.

M.R. Kharegat, Esqr., Assoc. M.Inst. C.E.,
Offg. Secretary to the Government,
of Madras, Chepauk, Madras.

Dear Sir,

We shall be glad if you will kindly let us have a reply to our letter of the 17th ult reference No. 53/4.

Yours faithfully,
The Bellary Electric Supply Co., Ltd.,

T. M. Rama Naidu
Managing
for

P.W.D

US.— With the reference above referred to, the Company forwarded 3 booklets of Conditions and rates. They have been referred to the E.I.C. for remarks. He was reminded on 19.3.25. His reply may be awaited till 8.4. ~~Tell them, no [illegible] reply [illegible]~~ meanwhile.

U.S.
30/3

reply
Urgent D/2
30/3
& on 28.2.25

Meanwhile an intermediate reply to the Bellary Electric Supply Coy. is put up.

for approval

1/iv/35

31/3

P.W.D.

Letter 675 A/25-2 d/ 3 $\frac{4}{25}$

To.

✓ The Managing Director

The Bellary Electric Supply Co. Ltd

Bellary.

APR 1925

Bellary Electric License. 1921

Sir,

p.1 C. With reference to your No. 53/5 of 30.3.1925, I am directed to inform you that the matter is under consideration.

I have etc.

3/4/25

for S.

UR

31/3/25

31/3

Pts

U

C.W. 175 A.D From Messers the Bellary Electric Supply Coy. Ltd

R 53/4 d/ 17-2-192

Urgent

forwarding for approval their ~~plan~~ booklet containing the form of Conditions, Rates & General Information for the Supply of electric energy under the Bellary Electric License, 1921.

[illegible]

Memo. 675

A Copy of the booklet referred to above is forwarded to the Chairma Municipal Council, Bellary, who is requested to obtai & submit at an early date the Council's remar thereon if any, with reference to Section 21(of the Indian Electricity Act 1910 as amended by the Indian Electricity (Amendment) Act, 1922. The booklet is based on the Model Form of Conditions Rates & General Informatio for the Supply of electric energy issued with G.O No 254 W d/ 26-2-1923,

(1) Issue
(2) File DTSQ(20)

Copies

X 5

Copies of which can be had from the Supdt. Govt. Press.

?
7.5.25

ACM
8.5.25

11/5/25

Dis. S. Do

16. 5.

The C.M.C. Bellary with one booklet to be returned with reply.

I D

R.D. one month

1/5/25

Memo no 285 GL-2
18/6/25

Conditions, Rules & General information for the supply of electric energy under the Bellary Electric Licence 1921. Memo no 675 MD/25-3 of 15/5/24

The attention of the Chairman, Municipal Council, Bellary is invited to the reference quoted above and he is requested to state when a reply may be expected.

Ams
18/6/25

18-6-25

Despd
19/6

To The Chairman, Municipal Council, Bellary

Do Remind in 2 weeks.

C.F. 29—5,000—17-12-23.

DEPARTMENT.

Received 29 JUN 1925 192 . *Registered* SECRETARIAT 1924 R 4-JUL 1925 192

Subject.

Regarding rules and conditions of Electric lighting.

18460 L.S.G

P.W.D. u.o

L.S. No. 18460 / 1
7.7.25 30/6

My Ser No. 153
7-25

ENCLOSURES.
No.
Spare copies

Station Bellary, *Dated the* 23rd June 1925.

From (Name) M.R.Ry. N. Narayana Rao Garu, B.A., B.L., F.M.U.,

(Designation) Chairman, Municipal council.

P.W.D.

L.o. 20-7-25

To The Secretary to the Government of Madras,

Local Self Government Department.

Madras.

Sir,

Referring to Government Memorandum No. 285-G.L.-2., dated 16-6-25, I have the honour to state that the Superintendent, Government Press, Madras has been applied ~~to~~ for a copy of G.O.No. 254 W., dated 26-2-25 referred to in - - Government Proceedings No. 675 A.D./25-3 dated 15-5-25. On receipt of which the matter will be placed before the meeting and the result intimated in due course.

I have the honour to be,

Sir,

Your most obedient servant,

Vice-Chairman. 24/6/25

24/6

PWP

8

Memo No 28581-3
27-7-25

Conditions Rules et
for the supply of Electric energ
under the Bellary Electric Licen
1921.

Desp 27/7

The attention of the Chairman, M.C., Bellary is invited to his letter Ref No 153/25-6-25 and he is requested to state whether the matter has been place before the Council &, if so, when a reply to this office memo No 675 AD/25-3 of 15-5-25 may be expected

p7·P

Trans
24/7/25

VVS 24-7-25

re Chairman
M.C., Bellary

28/7
Remind in 3 weeks

24/7

DCIAD
Please take action to amend the model form as suggested at on p.6 N.F. – It need not wait f the reply in this case

24/7

DCIAD
27/7

C.F. 29—5,000—17-12-23.

DEPARTMENT

SECRETARY TO GOVER... PUBLIC WO...
6 AUG 1925

Received..........192 . *Registered*..........192

Subject.

Regarding the conditions of the Electric license of the Bellary Electric Supply Co.,

---

ENCLOSURES.
No ....
Spare copies ....

No.

Station Bellary, *Dated the* 29th July 1925.

From (Name) M.R.Ry, N. Narayana Rao Garu, B.A., B.L., F.M.U.,

(Designation) Chairman, Municipal Council

To The Secretary to the Government of Madras,

Public Works Department.
Madras.

Sir,

With reference to Government Memorandum No.285-Gl-3 dated 27th July 1925, I have the honour to state that as the G.O. was not available in the office, the superintendent of Government Press had been addressed to send one. Even there it is not available. So after it is obtained the matter will be placed before the Council and it will be within a fortnight time.

I have the honour to be,
Sir,
Your most obedient servant,

G. Thimmappa 31/7/25
Vice-Chairman.

31-7-25

Dy No 1078

L. O. till 25-8-25

11/8/25

11-8-25

31/7

11/8

AS

10

P.W.D.

Urgent

Memo No 2558/25-4 d/ 26

Conditions, Rates etc fo
the supply of electric energ
under the Bellary Electric Lic
1921.

Pd 26/8

The attention of the
Chairman, M.C. Bell
is invited to his letter R
SCR No 153/ ~~20-9~~ 2-8 - 25
and he is requested to ~~expedi~~
his reply to this office mem
No 675 AD/25-3 of 15-5-2

am
26-8-25

am
26/8

To The Chairman,
M.C. Bellary

Fd Remind in 2 weeks.

27th aug

C.F. 29—5,000—17-12-23.

DEPARTMENT.

26358

Received........................192 . *Registered*........................192 .

SECRETARY TO GOVT.
11 SEP 1925

Subject.

conditions, rates etc., for the supply of el[illegible] energy L.S.G

L.S.G no 26358-1 Am
9.9.25.
8/9.

P.W.D. R.O.
Aug 9-9-25

ENCLOSURES.
No.
Spare copies

14 No.

Station Bellary, *Dated the* 30th August 1925.

From (Name) M.R.Ry. N. Narayana Rao Garu. B.A., B.L.,
F.M.U.,
(Designation) Chairman, Municipal Council,
Bellary.

To The Secretary to the Government of Madras,
Local self government Department.
Madras

Sir,

Referring to government memorandum No. 2?5 31.25--, dated 20-8-25, I have the honour to state that the subject will be placed for consideration of the council at its meeting to be held on the 5th September and a reply will be sent as soon as the meeting is over.

I have the honour to be,
Sir,
your most obedient servant
G. Thimmappa
Chairman. 31/8/25

Lo fill. 20-9-25
12/9/25
12/9
A.S.
DC 2
11/9

C.F. 29—5,000—17-12-23.

DEPARTMENT.

Received..............................192 . *Registered* 14-9 192

Subject.

Regarding conditions and rates of the Bellary Electric Supply company.

ENCLOSURES.

No.

Spare copies

No.

Station Bellary., *Dated the* 6th September 1925.

From (Name) M.R.Ry. N. Narayana Rao Garu. B.A.,B.L., F.M.U.,

(Designation) Chairman, Municipal Council,

Bellary.

To The Secretary to the Government of Madras,

Public Works Department.

General buildings and roads)

Madras.

Sir,

With reference to Government Memorandum No.075 A. D, 25-3 of the 15th May last, I have the honour to state that the council have in their resolution No. 4 dated 5-9-25 (copy enclosed) approved of the form of conditions, rates etc., for the supply of Electric Energy, contained in the booklet of the Bellary Electric Supply company, Bellary sent to me with the reference and returned herewith as desired therein.

I have the honour to be,

Sir,

Your most obedient servant

G.

V Chairman. 9/9/25

DC 2/ 14/9

Extract from proceedings of the ~~chairman~~ Municipal Council, Bellary, at the meeting held on 5th September 1925.

Dis 999/12-9-25

NO.4. Government memorandum No.675 A.D./25-3 dated 15th May 1925, forwarding a booklet containing the forms of conditions, rates etc., for the supply for Electric Energy under the Bellary Electric license 1921 with a request to obtain and submit remarks of the council thereon with reference to section 21(2) of the Indian Electricity Act 1910 as amended by the said Act of 1922.

Resolution.4 The council approves of the conditions and rates contained in the booklet issued by the Bellary Electric Company and accepts all the provisions therein contained.

(True copy)

(Sd) N. Narayana Rao.
Chairman.M.C.

G. Thimmappa

14 PWD

Letter No 285 gl-5
19-9-25

To
The Managing Director
The Bellary Electric Supply Co Ltd
Bellary

25th

Sir,

Bellary Electric Licence 1921. Conditions, Rates etc for the supply of electric energy

XD mri 21/9

p1 cp

Your letter No 53/4 d/17.2.25

The Govt ~~propose~~ are prepared to approve of the ~~pamphlet~~ conditions rates etc ~~received with your letter~~ as amended by them, and I am to request that 10 clean copies of the amended pamphlet may be printed & supplied. Orders approving the ~~same~~ them it will be issued on receipt of the copies.

76.i.L

I have etc

D-A on approving pamphlet as amended

16/9/25

16/9

16-9-25

for Ex. original to be retained in the office. A copy to be made for issue]

9D. R D one month

15 Letter No 285 GL-6
22-10 25

To
The Managing Director,
The Bellary El. Supp
Corporation
Bellary

DO
we
23/10

Sir,

p14 cf

Bellary Electric Licence 1921, conditions, rates etc for the supply of energy - Refce my letter No. 265 GL- of 21-9-25

I am to enquire wh the copies of the 'conditions, rates etc' asked for may be expected.

23 OCT 25
REC.

I have etc

[illegible]

All
22/10

V.H.
for Secy

22

RD 2 weeks

16

TELEPHONE No. .

TELEGRAMS,
"BESCO"

PLEASE QUOTE THIS OFFICE LETTER No. IN ALL YOUR COMMUNICATIONS.

THE BELLARY ELECTRIC SUPPLY Co., Ltd.,

S. M. HUSSAIN.
Managing Director.

6192 B
27 OCT

BELLARY, 24th Oct:25

Ref No.

F.B. Evans, Esq., C.I.E., I.C.S.,
Secretary to the Government of Madras, P.W.D.,
Fort St. George, MADRAS.

Sir,

Bellary Electric Licence, 1921, conditions,
rates etc. for the supply of energy.

We have to acknowledge the receipt of your letter dated the [illegible]nd inst. ref. No.285 EI-6 and in reply we beg to inform you that we have not yet received from our printers Messrs.Hoe & Co., Madras, the copies of the"conditions, rates, etc"., but the same will be posted to you as soon as we receive from our printers.

T.R/

Yours faithfully,

The Bellary Electric Supply Co., Ltd.,
T.M. Rama Naik
for Managing Director

Lo file 20.11.25

Dl 2/ 26/10

am
26/10/25 Alm 26/10

17/

PWD

Letter No 285 gl-7 / 20/11/25

To

The Managing Director
The Bellary El Supply
Corporation Ltd

Sir,

Bellary Electric License 1924 – Conditions, rates etc for the supply of energy – Your letter dated 24th Oct 25

p 16 cf

I am to enquire when the copies of the 'Conditions rates etc' asked for may be expected.

Am

20/11/25

20/11

2° 1800

Id

RD 3 weeks.

for Secy

The Electrical Engineer [illegible]

[illegible]

18

Letter PWD No 2858L-8
5.1.26

To

The Managing Director,
The Bellary El. Supply
Corporation Ltd
Bellary

Sir,

Bellary Electric License 1921 — Conditions rates etc for the supply of electric energy. — Refer my letter no 2858L-5 of 21-9-25 & the reminder dated the 20th Novr 25

p 11 c.f.
p 17 c.f.

I am to enquire when the printed copies of the conditions rates etc asked for may be expected

AW
57/26
5.1.26

5.1.26
for Secy

6 JAN 26
PWD

RD 3 weeks.

AS

Please see the pencil note at the foot of page 17 cf. Nothing further has been heard from the El. Inspr. abt the winding up of the Company. The Company may perhaps now be reminded

AW

19/

TELEPHONE No.

TELEGRAMS.
"BESCO"

PLEASE QUOTE THIS OFFICE LETTER No. IN ALL YOUR COMMUNICATIONS.

THE BELLARY ELECTRIC SUPPLY Co., Ltd.,

S. M. HUSSAIN.
Managing Director.

Ref No.

229 B
8 JAN 1926
PUBLIC WORKS DEPARTMENT

BELLARY, 6th Jan:26.

F.B.Evans,Esq., C.S.I., I.C.S.,
Secretary to the Government of Madras, P.W.D.
Fort St. George, M A D R A S.

Sir,

We beg to inform you that we have this day despatched under seperate cover 10 copies of the conditions, rates and general information for the supply of Electric energy and we shall be obliged if you will kindly approve of the same at your earliest convenience.

TMR/SV.

Yours faithfully,

The 1

D. N. Rama Naidu
for

D C v/
/ 8/1

Proof copy

THE BELLARY

Electric Supply Co., Ltd.

871, Goldsmith Staeet, BELLARY.

Conditions, Rates and General Information for the Supply of Electric Energy.

MADRAS:
PRINTED BY HOE CO. AT THE 'PREMIER' PRESS.

1925.

Contents.

Part I. page.

Conditions of supply 1

Part II.

Rates at which supply will be charged 6

Part III.

Scale of Miscellaneous charges 8

Part IV.

Form of Requisition for supply 10

Appendix A.-Extracts from the Indian Electricity Act 1910 11

Appendix B.-Extracts from the Schedule to the said Act 22

Appendix C.-Extracts from the Indian Electricity Rules, 1922. 28

Appendix D.-Form of Requisition for Supply of Energy 38

Appendix E.-Form of Agreement 39

CONDITIONS, RATES AND GENERAL INFORMATION FOR THE SUPPLY OF ELECTRIC ENERGY:

PART I.

CONDITIONS OF SUPPLY.

Application for supply.

1. Application for a supply of electrical nergy must be made to the Company upon the orm of requisition attached hereto (Appendix D) of which copies are obtainable at the Company's Office. The requisition must be signed by the owner or occupier of the premises. Assistance and information in filling up the form will be given to any applicant at the office.

Notice for fixing service and meter, etc.

2. Upon receipt of the application, notice will be sent to the consumer, or to the wiring contractor acting on the consumer's behalf, for his representative to meet the Company's Engineer to agree upon the position of the supply service, main cut-out and meters. The Company will in no case fix their meters and main cut-outs, nor allow the same to remain in any position which entails entry by the Company's employees into purdah or religious quarters.

Notice before connexion.

3. The intending consumer must give one month's notice before the supply is required.[1]

---

[1] This is the period prescribed in clause VI (1) of the Schedule to the Act, *Vide* extracts attached hereto (Appendix B). In the case of long services, where public streets require to be opened up at least six weeks' notice is necessary, in view of the Statutory Notice required by the Municipal Authorities. In other cases it may be possible to make the connection within less than the statutory period, and this will be done where possible. Special arrangements for connecting temporary illuminations will be made when possible, but as long notice as is practicable should be given.

Fixing position of services, meter boards and fuses.

4. The Company will lay the service lines between the distributing main and the consumer's premises. The size of these lines and of the meter boards and fuses will be determined by the Company's Engineer.

Consumer not to interfere with supply mains or apparatus.

5. The Company provide their own ~~serial~~ fuse, main meter boards, cut-outs, etc., and it must be clearly understood that these remain their property and must on no account be handled or removed by anyone who is not in the employ of the Company. The seals which are fixed on the meters and the Company's apparatus must on no account be broken or tampered with.

Fixing services and apparatus on consumers' premises.

6. Fixing of service lines, cables and fittings connected therewith (not including house wiring etc.), on consumers' premises can be undertaken by the Company at an authorized scale of charges which are given in Part III of this pamphlet.

Wiring on consumers' premises.

7. For the protection of consumers, and the public generally, it is necessary that the wiring on consumers' premises shall conform with the Indian Electricity Rules, 1922, and the Rules of the Fire Insurance Company in which the building is insured. The Company is unable to accept responsibility with regard to the maintenance or testing of wiring on consumers' premises. The adoption of the Regulations for the Electrical Equipment of Buildings issued by the Institution of Electrical Engineers or the specification issued by the Government of Madras for electrical work in Government Buildings is strongly recommended, especially as regards the method of carrying out metal sheathed wiring.

Position and construction of main switches and fuses.

8. The consumer must in all cases provide quick break main switches and a main fuse on each pole, which must be erected within three feet of the Company's meter board, or in such other position as shall be approved by the Company's Engineer.

Procedure for testing installation and fee.

9. (1) After completion of the wiring, 48 hours' notice must be sent to the Company (upon a printed test form obtainable from them) that the installation has been completed and tested by the Contractors, and that the same is complete and ready for inspection and test by the Company by whom only can the connexion be made. Notice of the Company's intention to inspect and test the installation will be sent to the Contractor, who must send a representative at the time fixed to give any information that may be necessary concerning the installation.

(2) No connection will be made until the consumer's installation has been inspected and tested by the Company and found satisfactory. No charge will be made for the first test made by the Company but subsequent tests due to faults disclosed at the initial test will be charged for in accordance with Part III of these conditions, paragraph 8.

(3) All fittings, whether lamps, fans, motors, heating or cooking apparatus, must be connected to the conductors and all fuses must be in place and all switches switched on before the tests are carried out.

(4) A pressure of 500 volts will be applied between the whole installation and "earth," and the insulation resistance after one minute's electrification shall not be less than the total

number of ohms arrived at by dividing the number 10,000,000 in the dry season, and 5,000,000 in the rainy season, by the number expressing the maximum electric current in amperes required.

(5) The test between the poles should give at least half the result of that to "earth."

Extensions and alterations.

10. Should the consumer, at any time after the supply of energy has been commenced, increase the number or size of lights, fans or motors, etc., on his premises, or in any way alter the position of his wiring therin, notice (in writing) must be sent to the Company whose representative will call and inspect the alteration and, if necessary, change the meters and fuses and alter the service line. Failure to give such notice may derange the supply system and render the supply liable to be summarily discontinued. During such times as alterations, additions or repairs are being executed the supply to the circuit which is being altered, added to or repaired must be entirely disconnected and it shall remain disconnected until the alterations, additions or repairs have been tetsed and passed by the Company.

Failure of supply.

11. Should the Company's main fuse melt, notice must be sent to the Company's Office; it may only be replaced by one of their authorized Assistants. (If the cause of its melting was due to a defect on the consumer's wiring a charge of Re. 1 ~~may~~ will be made.) No repairs need be done to consumer's wiring by the Company's Assistants.

Access to apparatus.

12. The Company's servants are entitled, at all reasonable times, to enter upon premises to which the energy is supplied for the purpose

of inspecting meters and for other purposes connected with apparatus belonging to the Company.

13. The Company may require any consumer to enter into a formal contract, and to deposit security for the payment for energy supplied, but in the event of no formal contract having been entered into between the Company and the consumer, the latter, after once the supply of electricity has commenced, shall be bound by the terms and conditions of supply herein set forth. **Agreement and security.**

14. The price and method of charging for current supplied shall be such as may from time to time be fixed by the Company, in accordance with the provisions of the Act and of their licence, or such as may be made the subject of special agreement between the consumer and the Company. **Method of charging for current.**

15. Consumers about to vacate or sub-let their premises should give the Company a full seven days' notice in writing, together with an opportunity for disconnecting the premises; otherwise the Company cannot guarantee that the meter readings will be taken on the required date. Failing such notice the consumer will be held responsible for energy consumed on the premises, in respect of which the Company holds his agreement for the supply of energy, until such date as notice of vacation in writing has been received at their Office. **Notice of removal.**

16. Supply for domestic purposes will be made at consumers terminals at the declared pressure of 220 volts; in particular cases, however, where large supplies are required (exceeding 10 amperes), special conditions[2] will **Pressure and amount of supply.**

---

[2] See proviso to section 21 (1) of the Act, in Appendix A, and second proviso to clause VI (1) of the Schedule to the Act, sub-head (*b*), in Appendix B hereto.

be imposed as provided in the following "Conditions."

17. (1) Motors and apparatus requiring more than 10 amperes will only be supplied across the outer conductors of a 3-wire system at 440 volts.

Lift motors.

(2) In order that the supply to other consumers shall not be interfered with[3] lift and other motors with a fluctuating load, having a rated amperage exceeding 10 amperes, will be supplied across 440 volts, and must therefore be suitably wound. Attention is also necessary to the conditions imposed by the Government of India, under ~~the Rules of~~ the Indian Electricity ~~Act,~~ Rules 1922, regarding medium and high pressure supply. For convenience of consumers these rules are printed at the end of this pamphlet (see Appendix C).

Saving clause as to Company's ~~lights.~~ rights.

18. Nothing in these conditions shall abridge or prejudice the rights of the Company under their licence and under the Acts of the Government of India or the Local Government, or any rule thereunder.

PART II.

RATES AT WHICH SUPPLY WILL BE CHARGED.

1. Electricity will be supplied at the rate of four annas per Board of Trade Unit, for Lights and Fans on combined circuit. For Lighting only, five annas per Board of Trade Unit. Bills will be rendered monthly in accordance with the meter readings entered by the Supply Company in a book attached to the meter, such book to be open for the inspection of the Consumer.

---

[3] See proviso to section 21 of the Act in Appendix A hereto.

Minimum Charge.

2. There will be a minimum charge of Rs. 2–3–0 per mensem for lighting installations and Rs. 3 for installations with Lights and Fans, exclusive of meter rent, whether energy is consumed or not.

Note.—Consumers are requested to give our meter readers every facility to take meter readings, as otherwise no adjustment of the minimum charge will be made on the subsequent bills.

Consumers with Large Consumption.

3. Reduced charges on a Sliding Scale will be allowed as follows :—

For the first	1,500 B. T. U. per month at 4 As. per unit [redacted] ✓		
For the excess above 1,500 and up to 3,000 B. T. U. per month at As.			3½
,, ,,	3,000 ,,	5,000 ,,	3
,, ,,	5,000 ,,	7,000 ,,	2¾
,, ,,	7,000	.. ..	2½

Motors.

(i) For any quantity not exceeding the equivalent of thirty-three hours' supply per month at the maximum power which has been demanded at the rate of four annas per unit.

(ii) For any quantity exceeding the equivalent of thirty-three hours' supply per month at such maximum power at the rate of three annas per unit.

(iii) For any further quantity exceeding the equivalent of sixty-six hours' supply per month at such maximum power at the rate of two annas per unit.

PART III

SCALE OF MISCELLANEOUS CHARGES, FOR SERVICE CONNECTIONS, TESTING, ETC.

Note.—The charges for the service line connecting an installation are payable before the work is carried out; No. (9) is payable before reconnection and No. 10 is payable at the time when the work is done.

Service Connections.

(1) For connecting up an installation the Company shall be entitled to charge the consumer the actual cost of materials and labour involved *plus* 15 per cent., subject to the provisions of clause VI (1) of the Schedule to the Act, first proviso, sub-head (*a*)* reprinted in Appendix B hereto.

(2) Extensions or additions to service lines, to meet increased maximum demand, will be charged for on the same basis.

In each case the consumer will be furnished with an estimate of the cost of the work, and the amount of this is payable in advance. On completion of the work, a bill for the actual amount payable will be forwarded to the consumer and any difference must be paid or refunded as the case may be.

Other Miscellaneous charges.

	RS.		
(3) For hire of meter, where it is the property of the Company per meter, per mensem of 10 amperes and above	1	0	0
Do. under 10 amperes.	0	8	0

---

*Under this clause, the Company provides the service line free of charge for a distance of 100 feet from his distribution mains so long as it is not on the consumer's property, i.e., up to the boundary of that property, if within 100 feet from the main.

Part 1V.

Form of Requisition for supply.

To The Bellary Electric Supply Co., Ltd, Bellary.

I hereby require you in accordance with Clause V1*of the Schedule to the Indian Electricity Act, 1910, within one month from the date of this requisition, to supply electrical energy for the premises.....................owned (occupied) by.................... being within the " area of supply" specified in the Bellary Electric License, 1921 for the following†--

Glow lamps (Wattage 17,20,30,40,60, etc.
(Number
Arc lamps. Number and wattage
Fans. Number and wattage
Cooking apparatus.- Number and wattage
Heaters.-------------- Number and wattage
Motors (Number
(Horse power of each

The wiring work will be carried out by...... ....(contractor)

Dated at..............
The....... day of......... 19

Signature.

---

*Where the requisition is signed on behalf of Government this should be stated here.

†The particulars should show under which of the tariffs the supply will be required, and also the ultimate application of the current to be supplied. The applicant should specify distinctly whether it is to be for "lighting only." "power purpose only" "lighting and fans only" or both "power and lighting and fans" "industrial power" etc.

Note.- In acknowledging receipt of a requisition the licensee should state the estimate cost of the service connection so far as it

P.T.

APPENDIX A.

EXTRACTS FROM THE INDIAN ELECTRICITY ACT, 1910.

Supply.

A licensee

Power for ~~the Company~~ licensee to enter premises and to remove fittings or other apparatus of ~~the Company~~ licensee.

Section 20. (1) ~~The Company~~ A licensee or any person duly authorized by ~~the Company~~ a licensee may, at any reasonable time, and on informing the occupier of his intention, enter any premises to which energy is or has been supplied by ~~the Company~~ the licensee, for the purpose of—

(*a*) inspecting and testing the electric supply-lines, meters, fittings, works and apparatus for the supply of energy belonging to the ~~Company~~ licensee ; or

(*b*) ascertaining the amount of energy supplied or the electrical quantity contained in the supply ; or

(*c*) removing, where a supply of energy is no longer required, or where the ~~Company~~ licensee is authorized to take away and cut off such supply, any electric supply-lines, meters, fittings, works or apparatus belonging to the ~~Company~~ licensee.

A licensee

(2) ~~The Company~~ or any person authorized as aforesaid may also, in pursuance of a special order in this behalf made by the District Magistrate or, in a Presidency-town or Rangoon, by the Commissioner of Police, and after giving not less than twenty-four hours' notice in writing to the occupier, enter any premises to which energy is or has been supplied, or is to be supplied by ~~the Company~~ licensee, for the purpose of examining and testing the electric wires, fittings, works and apparatus for the use of energy belonging to the consumer.

(3) Where a consumer refuses to allow the Company or any person authorized as aforesaid to enter his premises in pursuance of the provisions of sub-section (1) or sub-section (2), or, when such Company or person has so entered, refuses to allow him to perform any act which he is authorized by those sub-sections to perform, or fails to give reasonable facilities for such entry or performance, the Company may, after the expiry of twenty-four hours from the service of a notice in writing on the consumer, cut off the supply to the consumer for so long as such refusal or failure continues, but for no longer.

Restrictions on Company's controlling or interfering with use of energy.

Section 21. (1) The Company shall not be entitled to prescribe any special form of appliance for utilizing energy supplied by them or, save as provided by section 23, sub-section (2), or by section 26, sub-section (7), in any way to control or interfere with the use of such energy:

Provided that no person may adopt any form of appliance, or use the energy supplied to him, so as unduly or improperly to interfere with the supply by the Company of energy to any other person.

(2) Subject to the provisions of sub-section (1) the Company may, with the previous sanction of the Government ~~of Madras~~ given after consulting the local authority, where the Company is not the local authority, make conditions not inconsistent with this Act or with the Company's licence or with any rules made under this Act, to regulate the Company's relations with persons who are or intend to become consumers, and may with the like sanction given after the like consultation add to or alter or amend any such

conditions; and any conditions made by a ~~the~~ licensee ~~Company~~ without such sanction shall be null and void:

Provided that any such conditions made before the 23rd day of January 1922 shall, if sanctioned by the local Government ~~of Madras~~ on application made by the licensee ~~Company~~ before such date as the local Government ~~of Madras~~ may, by general or special order, fix in this behalf, be deemed to have been made in accordance with the provisions of this sub-section.

(3) The local Government ~~of Madras~~ may, after the like consultation, cancel any condition or part of a condition previously sanctioned under sub-section (2) after giving to the licensee ~~Company~~ not less than one month's notice in writing of its intention so to do.

(4) Where any difference or dispute arises as to whether the licensee ~~Company~~ has prescribed any appliance or controlled or interfered with the use of energy in contravention of sub-section (1), the matter shall be either referred to an Electric Inspector and decided by him or, if the licensee ~~Company~~ or consumer so desires, determined by arbitration.

Obligation on the ~~Company~~ licensee to supply energy.

Section 22. Where energy is supplied by a ~~the~~ licensee ~~Company~~, every person within the area of supply shall, except in so far as is otherwise provided by the terms and conditions of the licence, be entitled, on application, to a supply on the same terms as those on which any other person in the same area is entitled in similar circumstances to a corresponding supply:

Provided that no person shall be entitled to demand, or to continue to receive, from ~~the~~ licensee ~~Company~~ a supply of energy, for any premises having a separate supply unless he has agreed with the Company to pay them such minimum annual sum as will give them a reasonable return on the capital expenditure, and will cover other standing charges incurred by them in order to meet the possible maximum demand for those premises, the sum payable to be determined in case of difference or dispute by arbitration.

use ordinary type

Section 23. (1) The Company shall not, in making any agreement for the supply of energy, *show undue preference to any person*, but may, save as aforesaid, make such charges for the supply of energy as may be agreed upon, not exceeding the limits imposed by their licence.

Charges for energy to be made without undue preference.

(2) No consumer shall, except with the consent in writing of the Company use energy supplied to him under one method of charging in a manner for which a higher method of charging is in force.

(3) In the absence of an agreement to the contrary, the Company may charge for energy supplied by the Company to any consumer—

(*a*) by the actual amount of energy so supplied, or

(*b*) by the electrical quantity contained in the supply, or

(*c*) by such other method as may be approved by the Local Government ~~of Madras~~.

(4) Any charges made by the Company under clause (*c*) of sub-section (3) may be based upon, and vary in accordance with, any one or more of the following considerations, namely:—

(*a*) the consumer's load factor, or

(*b*) the power factor of his load, or

(*c*) his total consumption of energy during any stated period, or

(*d*) the hours at which the supply of energy is required.

Discontinuance of supply to consumer, neglecting to pay charge.

Section 24. (1) Where any person neglects to pay any charge for energy or any sum, other than a charge for energy, due from him to a ~~the Company~~ licensee in respect of the supply of energy, to him, the ~~Company~~ licensee may, after giving not less than seven clear days' notice in writing to such person and without prejudice to its ~~their~~ right to recover such charge or other sum by suit, cut off the supply and for that purpose cut or disconnect any electric supply line or other works, being the property of the ~~Company~~ licensee through which energy may be supplied, and may discontinue the supply until such charge or other sum, together with any expenses incurred by them in cutting off and re-connecting the supply, are paid, but no longer :

(2) Where any difference or dispute has been referred under this Act to an Electric Inspector before notice as aforesaid has been given by the ~~Company~~ licensee, the ~~Company~~ licensee shall not exercise the powers conferred by this section until the Inspector has given his decision.

Provided that the prohibition contained in this sub-section shall not apply in any case in which the ~~Company~~ licensee has made a request in writing to the consumer for a deposit with the Electric Inspector of the amount of the ~~Company's~~ licensee's charges or other sums in dispute or for the deposit of the ~~Company's~~ licensee's further charges for energy as they accrue and the consumer has failed to comply with such request.

Meters.

Section 26. (1) In the absence of an agreement to the contrary, the amount of energy supplied to a consumer or the electrical quantity contained in the supply shall be ascertained by means of a correct meter, and the Company shall, if required by the consumer, cause the consumer to be supplied with such a meter.

Provided that the Company may require the consumer to give them security for the price of a meter and enter into an agreement for the hire thereof, unless the consumer elects to purchase a meter.

(2) Where the consumer so enters into an agreement for the hire of a meter, the Company shall keep the meter correct, and, in default of their doing so, the consumer shall, for so long as the default continues, cease to be liable to pay for the hire of the meter.

(3) Where the meter is the property of the consumer, he shall keep the meter correct, and, in default of his doing so, the Company may, after giving him seven days' notice, for so long as the default continues, cease to supply energy through the meter.

(4) The Company or any person duly authorized by the Company shall, at any reasonable time and on informing the consumer of their intention, have access to, and be at liberty to inspect and test, and for that purpose, if they think fit, take off and remove, any meter referred to in sub-section (1); and, except where the meter is so hired as aforesaid, all reasonable expenses of,

and incidental to, such inspecting, testing, taking off and removing shall, if the meter is found to be otherwise than correct, be recovered from the consumer; and where any difference or dispute arises as to the amount of such reasonable expenses, the matter shall be referred to an Electric Inspector, and the decision of such Inspector shall be final:

Provided that the licensee ~~Company~~ shall not be at liberty to take off or remove any such meter if any difference or dispute of the nature described in sub-section (6) has arisen until the matter has been determined as therein provided.

(5) A consumer shall not connect any meter referred to in sub-section (1) with any electric supply-line through which energy is supplied by a licensee the Company, or disconnect the same from any such electric supply-line, without giving to the licensee Company not less than forty-eight hours' notice in writing of his intention.

(6) Where any difference or dispute arises as to whether any meter referred to in sub-section (1) is or is not correct the matter shall be decided, upon the application of either party, by an Electric Inspector, or by a competent person specially appointed by the Local Government ~~of Madras~~ in this behalf; and, where the meter has, in the opinion of such Inspector or person, ceased to be correct, such Inspector or person shall estimate the amount of the energy supplied to the consumer or the electrical quantity contained in the supply, during such time as the meter shall not, in the opinion of such Inspector or person, have been correct; and where the matter has been decided by any person other than the Electric Inspector, an appeal shall lie to the Inspector, whose decision

shall in every case be final: but, save as aforesaid, the register of the meter shall, in the absence of fraud, be conclusive proof of such amount or quantity.

Provided that, before either the Company or a consumer applies to the Electric Inspector under this sub-section, they shall give to the other party not less than seven days' notice of their intention so to do.

(7) In addition to any meter which may be placed upon the premises of a consumer in pursuance of the provisions of sub-section (1), the Company may place upon such premises such meter, maximum demand indicator or other apparatus as they may think fit for the purpose of ascertaining or regulating either the amount of energy supplied to the consumer, or the number of hours during which the supply is given, or the rate per unit of time at which energy is supplied to the consumer, or any other quantity or time connected with the supply.

Provided that the meter, indicator or apparatus shall not, in the absence of an agreement to the contrary, be placed otherwise than between the distributing mains of the Company and any meter referred to in sub-section (1):

Provided, also, that, where the charges for the supply of energy depend wholly or partly upon the reading or indication of any such meter, indicator or apparatus as aforesaid, the Company shall, in the absence of an agreement to the contrary, keep the meter, indicator or apparatus correct; and the provisions of sub-sections (4), (5), and (6) shall in that case apply as though the meter, indicator or apparatus were a meter referred to in sub-section (1).

Explanation.—A meter shall be deemed to be "correct" if it registers the amount of energy supplied, or the electrical quantity contained in the supply, within the prescribed limits of error, and a maximum demand indicator or other apparatus referred to in sub-section (7) shall be deemed to be "correct" if it complies with such conditions as may be prescribed in the case of any such indicator or other apparatus.

NOTE.—(i) A meter of a type included in the specification herein referred to shall be deemed to be "correct" when its limits of error as certified by an Electric Inspector do not exceed those laid down in the "British Standarad Specification for Electricity Meters No. 37, dated 1919" and when it cannot register at no load and any meter, maximum demand indicator or other apparatus for which there is for the time being no British Standard Specification shall be deemed to be "correct" when its limit of error, as certified by an Electric Inspector, does not exceed 3 per cent above or below absolute accuracy at all loads in excess of one-tenth of full load and up to full load and when it cannot register at no load.

The following limits of error at the standard or marked temperature, pressure, frequency and at unitly power factor are laid down in the specification referred to, viz. :—

Load.	Permissible error.	
	Meters without external shunts or transformers.	Meters with external shunts or transformers.
	Per cent from true reading.	
Full load to one-fifth full load inclusive.	+ or — 2	+ or — 2·5
From one-fifth to one-tenth full load ..	+ or — 2·5	+ or — 2·5
At one-twentieth full load	+ or — 4·5	+ or — 5·0

(ii) When current or potential transformers or shunts are employed the accuracy specified shall be obtained with combined calibration.

(iii) If auxiliary apparatus is to be connected to the transformer or shunt the meter should be calibrated with all such apparatus connected.

Appointment of Electric Inspectors.

Section 36. (1) The Governor-General in Council may, by notification in the *Gazette of India*, appoint duly qualified persons to be Electric Inspectors, and every Electric Inspector so appointed shall exercise the powers and perform the functions of an Electric Inspector under this Act within such areas and subject to such restrictions as the Governor-General in Council may direct.

(2) The Local Government may, by notification in the local official Gazette, appoint duly qualified persons to be Electric Inspectors within such areas as may be assigned to them respectively; and every Inspector so appointed shall exercise the powers and perform the functions of an Electric Inspector under this Act, subject to such restrictions as the Local Government may direct.

(3) In the absence of express provision to the contrary in this Act or any rule thereunder, an appeal shall lie from the decision of an Electric Inspector to the Governor-General in Council or the Government ~~of Madras~~ as the case may be; or, if the Governor-General in Council or the Government ~~of Madras~~ as the case may be, by general or special order, so directs, to an Advisory Board.

Criminal Offences and Procedure.

Theft of energy.

Section 39. Whoever dishonestly abstracts, consumes or uses any energy shall be deemed to have committed theft within the meaning of the Indian Penal Code; and the existence of artificial means for such abstraction shall be *prima facie* evidence of such dishonest abstraction.

Penalty for interference with meters or ~~Company's~~ licensee's works and for improper use of energy.

Section 44. Whoever—

(*a*) connects any meter referred to in section 26, sub-section (1), or any meter, indicator or apparatus referred to in section 26, sub-section (7), with any electric supply-line through which energy is supplied by ~~the Company~~ a licensee, or disconnects the same from any such electric supply-line, without giving to the ~~Company~~ licensee forty-eight hours' notice in writing of his intention ; or

(*b*) lays, or causes to be laid, or connects up any works for the purpose of communicating with any other works belonging to ~~the Company~~ a licensee without such ~~Company's~~ licensee's consent ; or

(*c*) maliciously injures any meter referred to in section 26, sub-section (1), or any meter, indicator or apparatus referred to in section 26, sub-section (7), or wilfully or fraudulently alters the index of any such meter, indicator or apparatus, or prevents any such meter, indicator or apparatus from duly registering ; or

(*d*) improperly uses the energy of the ~~Company~~ licensee ; shall be punishable with fine which may extend to five hundred rupees, and, in the case of a continuing offence with a daily fine which may extend to fifty rupees ; and if it is proved that any artificial means exist for making such connexion as is referred to in clause (*a*) or such communication as is referred to in clause (*b*) or for causing such alteration or prevention as is referred to in clause (*c*) or for facilitating such improper use as is referred to in clause (*d*) and that the meter, indicator or apparatus is under the custody or control of the consumer, whether it is his property or not, it shall be presumed until the contrary is proved that such connexion, communication, alteration, prevention, or improper use, as the case may be, has been knowingly and wilfully caused by such consumer.

APPENDIX B.

EXTRACTS FROM THE SCHEDULE TO THE INDIAN ELECTRICITY ACT, 1910 (EXCEPT IN SO FAR AS THE SAME MAY BE ADDED TO, VARIED OR EXCEPTED IN ANY LICENCE).

Requisition for supply to owners or occupiers in vicinity.

Clause VI. (1) Where after distributing mains have been laid down under the provisions of clause IV or clause V and the supply of energy through those mains or any of them has commenced a requisition is made by the owner or occupier of any premises situate within the area of supply requiring the Company to supply energy for such premises, the Company shall, within one month from the making of the requisition, or within such longer period as the Electric Inspector may allow supply and, save in so far as he is prevented from doing so by cyclones, floods, storms, or other occurrences beyond their control, continue to supply energy in accordance with the requisition : ✓

Provided, first, that the Company shall not be bound to comply with any such requisition unless and until the person making it—

(*a*) within fourteen days after the service on him by the Company of a notice in writing in this behalf, tenders to the Company a written contract, in a form approved by the Government ~~of~~ Madras duly executed and with sufficient security, binding himself to take a supply of energy for not less than two years to such amount as will produce, at current rates charged by the Company, a reasonable return to the Company, and. ✓

(*b*) if required by the ~~Company~~ licensee so to do, pays to the ~~Company~~ licensee the cost of so much of any service line as may be laid down or placed for the purposes of the supply upon the property in respect of which the requisition is made, and of so much of any service line as it may be necessary for the said purposes to lay down or place beyond one hundred feet from the ~~Company's~~ licensee's distributing main, although not on that property:

Provided, secondly, that the ~~Company~~ licensee shall be entitled to discontinue such supply—

(*a*) if the owner or occupier of the property to which the supply is made has not already given security, or if any security given by him has become invalid or insufficient, and such owner or occupier fails to furnish security or to make up the original security to a sufficient amount, as the case may be, within seven days after the service upon him of notice from the ~~Company~~ licensee requiring him so to do, or

(*b*) if the owner or occupier of the property to which the supply is made adopts any appliance or uses the energy supplied to him by the ~~Company~~ licensee for any purposes, or deals with it in any manner, so as unduly or improperly to interfere with the efficient supply of energy to any other person by the ~~Company~~ licensee, or

(*c*) if the electric wires, fittings, works and apparatus in such property are not in good order and condition, and are consequently likely to affect injuriously the use of energy by the ~~Company~~ licensee, or by other persons, or

(*d*) if the owner or occupier makes any alterations of, or additions to, any electric wires, fittings, works or apparatus within such property as aforesaid, and does not notify the same to the Company before the same are connected to the source of supply, with a view to their being examined and tested: but the Company shall re-connect the supply with all reasonable speed on the cessation of the act or default or both, as the case may be which entitled them to discontinue it.

Provided, thirdly, that the maximum rate per unit of time at which the owner or occupier shall be entitled to be supplied with energy shall not exceed what is necessary for the maximum consumption on his premises, and, where the owner or occupier has required the Company to supply him at a specified maximum rate, he shall not be entitled to alter that maximum, except after one month's notice in writing to the Company, and the Company may recover from the owner or occupier any expenses incurred by him by reason of such alteration in respect of the service lines by which energy is supplied to the property beyond one hundred feet from the Company's distributing main, or in respect of any fittings or apparatus of the Company upon that property: and

Provided, fourthly, that, if any requisition is made for a supply of energy and the Company can prove to the satisfaction of an Electric Inspector,—

(*a*) that the nearest distributing main is already loaded up to its full current-carrying capacity, or

(*b*) that, in case of a larger amount of current being transmitted by it, the loss of pressure will seriously affect the efficiency of the supply to other consumers in the vicinity;

licensee

the ~~Company~~ may refuse to accede to the requisition for such reasonable period, not exceeding six months, as such Inspector may think sufficient for the purpose of amending the distributing main or laying down or placing a further distributing main.

(2) Any service line laid for the purpose of supply in pursuance of a requisition under sub-clause (1) shall, notwithstanding that a portion of it may have been paid for by the person making the requisition, be maintained by the ~~Company~~. licensee ✓

(3) Where any difference or dispute arises as to the amount of energy to be taken or guaranteed as aforesaid, or as to the cost of any service line or as to the sufficiency of the security offered by any owner or occupier, or as to the improper use of energy, or as to any alleged defect in any wires, fittings, works or apparatus, or as to the amount of the expenses incurred under the third proviso to sub-clause (1), the matter shall be referred to an Electric Inspector and decided by him.

(4) Every requisition under this clause shall be signed by the maker or makers thereof and shall be served on the ~~Company~~. licensee ✓

(5) Every requisition under this clause shall be in a form* to be prescribed by rules under the Indian Electricity Act, 1910; and copies of the form shall be kept at the office of the licensee ~~Company~~ and supplied free of charge to any applicant.

Charges.

Methods of charging. Clause X. (1) Where the ~~Company~~ charges by any method approved by the Government ~~of Madras~~ in accordance with section 23, sub-section ~~(2), clause (c) of the Indian Electricity Act,~~

---

* See Appendix D.

1910, any consumer who objects to that method by not less than one month's notice in writing, require the Company to charge him, at the Company's option, either by the actual amount of energy supplied to him or by the electrical quantity contained in the supply, and thereafter the Company shall not, except with the consent of the consumer, charge him by another method :

(2) Before commencing to supply energy through any distributing main, the Company shall give notice, by public advertisement, of the method by which they propose to charge for energy so supplied ; and, where the Company has given such notice, they shall not be entitled to change that method of charging without giving not less than one month's notice in writing of such change to the Government ~~of Madras~~ to the local authority (if any) concerned, and to every consumer of energy who is supplied by them from such distributing main :

(3) If the consumer is provided with a meter in pursuance of the provisions of section 26, sub-section (1), of the Indian Electricity Act, 1910, and the Company changes the method of charging for the energy supplied by the Company from the distributing main, the Company shall bear the expense of providing a new meter, or such other apparatus as may be necessary by reason of the new method of charging.

Maximum charges.

Clause XI. Save as provided by clause IX, sub-clause (3), the prices charged by the Company for energy supplied by the Company shall not exceed the maxima fixed by the Company's licence, or, in the case of a method of a charge local

approved by the Government ~~of Madras~~, such maxima as the Government ~~of Madras~~ shall fix on approving the method :

Provided that, if at any time after the expiration of seven years from the commencement of the licence, the Government ~~of Madras~~ considers that the maxima so fixed or approved as aforesaid should be altered, it shall refer the matter to an Advisory Board and, if the Board recommends any alteration, may make an order in accordance with such recommendation, which shall have effect from such date as may be mentioned therein :

Provided, also, that, where an order in pursuance of the foregoing proviso has been made, no further order altering the maxima fixed thereby shall be made until the expiration of another period of five years.

A licensee ✓

Minimum charges.

XI-A. ~~The Company~~ may charge a consumer a minimum charge for energy of such amount and determined in such manner as may be specified by ~~their~~ his licence, and such minimum charge shall be payable notwithstanding that no energy has been used by the consumer during the period for which such minimum charge is made.

Charge for ✓

Supply for public lamps.

licensee

Clause XII. The price to be charged by the Company and to be paid to them for energy supplied for the public lamps, and the mode in which those charges are to be ascertained, shall be settled by agreement between the Company and the Government ~~of Madras~~ or the local authority, as the case may be, and where any difference or dispute arises, the matter shall be determined by arbitration.

APPENDIX C.

EXTRACTS FROM THE INDIAN ELECTRICITY RULES, 1922.

Conditions of Supply by the Company.

Precautions against leakage before connexion.

23. (1) The Company shall not connect the conductors and fittings on a consumer's premises with their works unless they are is reasonably satisfied that the connexion will not at the time of making the connexion cause a leakage from those conductors and fittings exceeding one five-thousandth part of the maximum supply demanded on the consumer's premises.

(2) Where the Company declines to make a connexion, in accordance with sub-rule (1), the Company shall serve upon the consumer a notice stating their reason for so declining.

Leakage on consumer's premises.

24. (1) If at any time the Company has reasons to believe that a leakage, likely injuriously to affect the use of energy by the Company or by other persons, exists in the premises of a consumer then the Company may give the consumer reasonable notice in writing, that the Company desires to inspect and test such wires and fittings belonging to the consumer as form part of the circuit.

(2) If the consumer does not give all reasonable facilities for inspection and testing, or if a leakage from the consumer's conductors exceeding one five-thousandth part of the maximum supply demanded on the premises is discovered, the Company may forthwith discontinue the supply of energy to the premises in question,

giving immediate notice of the discontinuance to the consumer, and need not recommence the supply until the cause of the leakage has been removed.

Appeal to Electric Inspector in regard to leakage.

25. (1) Where a consumer is dissatisfied with the action of ~~the~~ a licensee Company under rule 23 or rule 24 in refusing or in discontinuing, or in not recommencing the supply of energy to his premises, the conductors and fittings of such consumer shall, on his application and on payment of the prescribed fee, be tested for the existence of leakage by an Electric Inspector or other officer appointed to assist an Electric Inspector.

(2) Any such test as is referred to in sub-rule (1) shall be carried out within 48 hours of the application to make the same or on the payment of the prescribed fee, whichever is later.

(3) If the Electric Inspector or other officer as aforesaid on testing, finds that the leakage from the consumer's conductors is less than one five-thousandth part of the maximum supply demanded on the premises, the Electric Inspector shall notify the Company, and the Company shall within 24 hours commence or continue the supply of energy: Provided that in this case the licensee Company shall refund the amount of the prescribed fee to the consumer.

(4) This rule shall be endorsed on every notice given under the provisions of rule 23 or rule 24.

Declared pressure of supply to consumers.

26. Before commencing to supply energy to a consumer, ~~the~~ Company shall declare to the consumer the pressure at which ~~the~~ Company undertakes to give the supply; and the pressure

shall not, without the written consent of the consumer or the previous sanction of the Government of Madras vary therefrom by more than 5 per cent. in the case of low or medium pressure, or by more than 12½ per cent. in the case of high pressure.

Declared frequency of supply to consumers.

27. Before commencing to supply energy to a consumer by means of an alternating current, the Company shall declare to the consumer the frequency at which the Company undertakes to give the supply; and the frequency shall not, without the written consent of the consumer or the previous sanction of the Local Government ~~of Madras~~ vary therefrom by more than 4 per cent.

Examination of Company's records by consumer.

28. A consumer may, after giving not less than 24 hours' notice to the Company, enter any testing station established by the Company in accordance with clause XIII of the Schedule to the Act, and may examine the records of the test made therein; and he may also take copies of or extracts from such records on payment to the Company of a sum of one rupee for every such examination of a record covering a period of 24 hours or any part of 24 hours.

Sealing of meters.

29. The Company may affix a seal to any meter maximum demand indicator, or other apparatus placed upon a consumer's premises in accordance with section 26 of the Act, and to any cut-out placed upon a consumer's premises in accordance with rule 38 and no person shall break such seal without giving the Company and, where the meter is the property of the consumer, the consumer also not less than forty-eight hours' notice in writing.

Electric supply-lines.

Maintenance.

41. Every electric supply-line shall be maintained in a safe condition as regards both electrical and mechanical conditions by the person to whom the same belongs.

Accidental charge.

42. All circuits and apparatus shall be so arranged by the person to whom the same belong that there shall be no danger of any part thereof becoming accidentally charged to any pressure beyond the limits of pressure for which it is intended

Cut-out.

44. Every electric supply-line (other than the earthed neutral conductor of any system or the earthed external conductor of a concentric cable) shall be protected, by the person to whom the same belongs by a suitable cut-out.

Metal casings.

45. All metal casings or metallic coverings containing or protecting any electric supply-line or apparatus shall be connected with earth, by the person to whom the same belong and shall be so joined and connected across all junction-boxes and other openings as to make good mechanical and electrical connexion throughout their whole length :

Provided that this rule shall not apply to isolated wall tubes or to brackets, electroliers standards, switch or fan regulator covers or other fittings (other than portable hand lamps in factories) where the supply is of low pressure

Connexion with earth of frames of generators, etc.

46. The frame of every generator, stationary motor, and, so far as is practicable, portable motor, and the metallic parts (not intended as conductors) of all transformers and regulating or controlling apparatus connected with the supply shall be connected with earth by two separate and distinct connexions with earth.

Medium or High Pressure.

51. Where energy is to be supplied or used at medium or high pressure notice shall be given to an Electric Inspector and the supply shall not be commenced, or continued, until or unless the following provisions have been or are complied with, namely :— **Supply at medium or high pressure.**

(*a*) all live parts of apparatus shall, unless accessible only to, and under the control of, an authorized person, be protected by mechanically strong metal casing or metallic covering securely fastened throughout ;

(*b*) suitable linked switches of requisite capacity to carry and break the current shall be inserted in each conductor, near the point of origin on the consumer's or owner's premises, as the case may be ;

(*c*) every conductor, unless only accessible to an authorized person, shall be as far as is practicable, completely enclosed in a mechanically strong metal casing or metallic covering, securely fastened throughout or fixed in such other manner as may be approved in writing by an Electric Inspector ;

(*d*) the supply to every apparatus shall be efficiently controlled by suitable linked switches of requisite capacity to carry and break the current in each conductor placed near the apparatus in such a position as to be readily handled by the operator so that by their means all pressure can be cut off from the apparatus concerned and from any device in connexion therewith ;

(*e*) the word 'caution' both in English and in the Vernacular, shall be affixed in a conspicuous position near every generator (being the property of an owner) and near every motor, and every controlling or regulating apparatus in connexion with the same.

Introduction of multi-wire system to buildings.

52. Where the conductors of a multi-wire system between any of which there is medium or high pressure, are brought into a building for utilization at low pressure, the supply shall be delivered to two or more pairs of terminals, and the wiring from those terminals shall be kept separate and distinct. If in any such case two or more switches, terminals or cut-outs between any of which there is a difference of pressure exceeding 250 volts, are fitted within reach of one another, all their live parts shall be accessible only to authorized persons.

Main switch board.

53. Where the pressure is medium or high there shall be, in front of every main switch board, a space of not less than 3 feet in width, and, if there are any attachments or bare connexions at the back of the switch board, the space (if any) behind the switch board, shall be either less than 9 inches, or more than 30 inches in width, measured from the furthest outstanding part of any attachment or conductor. If the space behind exceeds 30 inches in width there shall be a passage way clear to a height of not less than 6 feet, save as regards any horizontal supports of the switch boards, which may be placed at a height of not less than 4 feet 6 inches.

Distinction of circuits of different pressure.

54. In every generating station or sub station, junction box or pillar in which there are any circuits or apparatus intended for medium as well as high pressure, the respective circuits shall be made readily distinguishable from one another.

High pressure.

Approval of high pressure supply.

55. (1) A high pressure supply shall not be delivered to any person, other than a distributing Company, except with the approval in writing of an Electric Inspector, and subject to such conditions (if any) as such Inspector may think reasonable and proper in the circumstances, and the installation shall not be brought into use until it has been inspected by an Electric Inspector or other officer appointed to assist an Electric Inspector.

(2) Where energy is to be used by an owner at high pressure, the installation shall not be brought into use except with the approval in writing of an Electric Inspector and subject to such conditions (if any) as he may think reasonable and proper in the circumstances.

(3) When the position of a high pressure motor or other apparatus is changed, notice shall forthwith be given to the Electric Inspector showing the extent and nature of the change of position.

Testing of insulation of all parts of high-pressure circuit.

56. (1) A high pressure circuit other than an aerial line shall not be brought into use unless the insulation of every part thereof has withstood the continuous application, during one minute in the case of every electric supply-line, machine, device or apparatus of a pressure 100 per cent. greater than the maximum pressure to which it is intended to be subjected in use; and the Company or owner, as the case may be, shall duly record the results of each test and shall forward the result to an Electric Inspector.

Provided, first, that the testing pressure shall in no case be less than 2,000 volts :

Provided, secondly, that an Electric Inspector, may, if he thinks fit, accept the manufacturer's certified tests as complying with this rule

Provided, thirdly, that where the normal working pressure exceeds 6,600 volts, the testing pressure need not exceed the working pressure.

(2) A high pressure electric supply-line shall during its use continue in the sole charge of an authorized person.

High pressure electric supply-lines and apparatus placed above ground.

57. All high pressure apparatus, including every portion of any high pressure electric supply-line (other than an ærial line) placed above the surface of the ground otherwise than in a sub-station, or in a compartment specially arranged for the purpose and accessible only to authorized persons, shall be completely enclosed in, or protected by, a mechanically strong metal casing or metallic covering securely fastened throughout; and all circuits and apparatus in connexion with the same shall be marked, at frequent intervals with the word 'caution,' both in English and in the vernacular.

Aerial Lines.

Height from ground and distance from buildings.

62. (1) No conductor of an aerial line (not being a trolley wire or a traction feeder on the same support as a trolley wire) erected in, over, along or across, any street shall be at a less height from the ground than 20 feet.

(2) No such conductor shall be accessible, either from the ground or from any permanent structure, except by the aid of a ladder or other special appliance.

Insert as in
attached sl.

(3) Where permanent or temporary additions or alterations made in or upon any building or structure, subsequent to the erection of the

2) No such conductor shall be accessible, either from the ground or from any building or structure whether permanent or temporary, except by the aid of a ladder or other special appliance.

(3) (a) If, at any time subsequent to the erection of an aerial line, any person proposes to erect a new building or structure whether permanent or temporary, or to make in or upon any building or structure any permanent or temporary addition or alteration, he shall, if such building, structure addition or alteration would render the aerial line accessible otherwise than by the aid of a ladder or other special appliance, give notice in writing of his intention to the licensee or owner, as the case may be, and to the Electric Inspector and shall furnish therewith a scale drawing showing the proposed building, structure, addition or alteration and the scaffolding required during its construction, and shall not commence work upon the building, structure, addition or alteration until the Electric Inspector has certified that neither during nor after the execution of the work will the aerial line be so accessible.

as to contravene the provision of Sub-rule (2) either during or after the execution of the work and may recover the reasonable cost of such alteration from the person from whom the notice was received; Provided that the licensee or owner as the case may be, may, before so altering the aerial line, require the person from whom the notice was received to deposit the estimated cost of such alteration. Provided further that an Electric Inspector may, if he is satisfied that the aerial line has been so guarded as to secure the protection of persons and property from injury or risk of injury, permit the work to be executed prior to, or, in the case of a temporary addition or alteration, without the alteration of the aerial line.

aerial line, cause this rule to be infringed; the Company or owner (as the case may be) shall so alter the said line as to comply with this rule, and may recover the reasonable cost of the work from the person responsible for making the said addition or alteration

(4) Where an aerial line is on a consumer's or an owner's premises, the height from the ground, or from any mineral or refuse dump, and from parts of buildings or structures to which persons have access shall (unless the conductors are adequately guarded) be not less than 15 feet or such greater height as may be necessary to prevent danger.

Penalties and Miscellaneous.

105. Companies and owners and their agents and managers shall be responsible for the observance of such of the rules in chapter V of these rules as impose a duty on a person not therein specified. **Responsibility for observance of rules**

106. Where in contravention of rule 29 any seal referred to in that rule is broken, the consumer upon whose premises the seal was placed shall be punishable with fine which may extend to fifty rupees. **Penalty for breaking seal**

107. Whoever, being a Company or owner, or the agent or manager of a Company, or owner, commits a breach of these rules shall be punishable for every such breach with fine which may extend to three hundred rupees and in the case of a continuing breach with a further fine which may extend to fifty rupees for every day after the first during which he is convicted of having persisted in the breach. **Penalty for breach of rules.**

Mode of entry

108. All persons entering, in pursuance of the Act or these rules any building which is used as a human dwelling or a place of worship shall, in making such entry, have due regard, so far as may be compatible with the exigencies of the purpose for which such entry is made, to the social and religious usages of the occupant of the building entered.

109. Subject to the provisions of section 58, sub-section (2) of the Act, these rules shall be binding on all persons, companies and undertakings to whom licences have been granted or with whom agreements have been made by or with the sanction of Government for the supply or use of electricity before the commencement of the Act.

Appendix D.

Form of Requisition under clause V1 (5) of the Schedule to the Act.

To The Bellary Electric Supply Co., Ltd.,Bellary.

I hereby require you, in accordance with clause V1 of the schedule to the Indian Electricity Act 1910, within one month from the date of this requisition, or within such londer period as the Electric Inspector may allow, to supply electrical energy for the premises..........................
............................owned (occupied) by me being within the "area of supply" specified in the Bellary Electric License 1921 for the following.-

The wiring work will be carried out by.....
....

Dated at.........
The day of 19

Signature.

Note.- Under Clause V1(1) first proviso,subhead(b) of the schedule to the Indian Electricity Act 1910, the licensee shall not be bound to comply with any such requisition unless and until the person making it.......... if required by the licensee so to do, pays to the licensee the cost of so much of any service line as may be laid down or placed for the purposes of the supply upon the property in respect of which this requisition is made and of so much of any service line as it may be necessary for the said purposes to lay down or place beyond one hundred feet from the licensee's distributing main, although not on that property.

APPENDIX D

FORM OF REQUISITION FOR SUPPLY.

TO THE BELLARY ELECTRIC SUPPLY Co., Ltd., BELLARY.

I hereby require you in accordance with clause VI* of the Schedule to the Indian Electricity Act, 1910, within one month from the date of this requisition, to supply electrical energy for the premises———————————————————owned (occupied) by——— being within the "area of supply" specified in the Bellary Electric Licence, 1921, for the following † :—

Glow lamps { Wattage 17, 20, 30, 40, 60, etc.
Number }

Arc lamps : number and wattage
Fans : number and wattage
Heaters : number and wattage
Cooking apparatus, number and wattage
Motors { Number
Horsepower of each }
The wiring work will be carried out by——————————(contractor).
Dated at——————————
The——————day of 19

(Signature)

---

*Where the requisition is signed on behalf of Government, this should be stated here.

† The particulars should show under which of the tariffs the supply will be required, and also the ultimate application of the current to be supplied. The applicant should specify distinctly whether it is to be for "lighting only" "power purpose only," "lighting and fans only" or both "power and lighting and fans" "industrial power," etc.

Note.—In acknowledging receipt of a requisition, the Company should state the estimate cost of the service connexion so far as it is payable" by the consumer subject to adjustment on completion of the work.

APPENDIX F.

~~MODEL~~ FORM OF AGREEMENT

AGREEMENT made day of One thousand nine hundred and Between The Bellary Electric Supply Co., Ltd.,
(hereinafter referred to as the Company) of the one part, and
(hereinafter referred to as the consumer) of the other part,

WHEREBY it is agreed as follows :

1. The Company shall furnish to the consumer and the consumer shall accept at the premises mentioned in the Schedule hereto on and from the date on which the said premises shall be connected with the Company's distributing main a constant supply of electrical energy for the purposes and up to the maximum specified and under the conditions laid down in the said Schedule. But the Company will not be responsible for any interruption or diminution of the supply due to occurrences beyond the control of the Company. ~~in the commencing period of the Company's undertaking the supply will be restricted to certain night hours of which due public notice will be given.~~

2. The consumer shall pay to the Company on demand the cost of so much of any service-line as may be laid down or placed for the purposes of the supply upon the said premises, and of so much of any service-line as it may be necessary for the said purposes to lay down or place beyond 100 feet from the Company's distributing main, although not on the said premises.

3. The supply shall be registered by a meter or meters in or upon the said premises to be provided fixed and kept in proper order by the Company. The consumer shall

pay to the Company for each meter on hire; the monthly rent of Re. 1 per meter of 10 amperes and above and As. 8 under 10 amperes. The consumer shall be at liberty at any time to purchase such meter or meters from the Company, and from and after the purchase thereof the consumer shall be responsible for keeping the same in proper order.

4. The consumer shall pay to the Company for all electrical energy so supplied at the rates, and in accordance with the terms, given in the Company's Current Official Scale of Rates and the signing of this Agreement is held to imply concurrence in the terms of the said Scale of Rates :-

Provided nevertheless that if at the end of twelve calendar months from the date of commencement of supply, and at the end of each subsequent period of twelve calendar months during which this Agreement is

Provided that should the value of the energy consumed in any one month be less than Rs.2-3-0 for lighting installations or Rs.3 for installations with lights and fans the consumer shall pay for that month a minimum charge of Rs.2-3-0 or Rs.3 as the case may be, whether energy is consumed or not, exclusive of meter rent

sumption being guaranteed then should the value of the energy consumed be less than the amount (if any) specified in the licence, the consumer shall pay to the Company a sum equivalent to the minimum sum so specified.

5. A consumer under this Agreement is required to state (see schedule) under which of the rates, set out in the Company's Official Book of Rates, he desires to be charged.

6. Readings of the meter or meters will be taken by the Company once in each month, or at such other

intervals or times as they shall think expedient, and the Company's meter-readers shall have access to the consumer's premises at all reasonable times for the purpose of taking such readings. The readings of each meter shall be entered by the Company in a book to be attached to such meter and to be open for the inspection of the consumer. Payment for energy supplied shall be made by the consumer according to the readings of each meter forthwith upon such readings being entered in the said book.

7. If the consumer shall at any time consider that any meter (not being his own property) is not in proper order for correctly registering the value of the supply, the Company will on receipt of a notice in that behalf from the consumer take the necessary steps to have the same tested; if, however, the consumer intends that the meter be tested by the Electrical Inspector to Government he shall give the Company not less than seven days' notice of his intention so to do. If upon such test it shall be found that the meter registers the supply within the limits of error prescribed in rule (2) (*u*) of the Indian Electricity Rules, 1922, the consumer shall repay to the Company on demand all costs of and incidental to such testing. If upon such test it shall be found that the meter registers the supply in excess of the limits of error, all costs of, and incidental to, such testing shall be borne by the Company; the Company shall refund to the consumer any amount paid by him in respect of the quantity registered in excess during the previous three months computed on the basis of the total error or difference from absolute accuracy disclosed by such test; and correspondingly the consumer shall pay to the Company on demand for the quantity short registered by such meter during the previous three months computed on the basis of the error or difference disclosed by such test. For so long as the meter (being the property of the Company) shall not be correct the consumer shall not be liable for the hire thereof.

8. The consumer has deposited with the Company the sum of Rs.   as security for the purpose next hereinafter mentioned, and shall on the like requisition from time to time renew or replenish such security in the event of the same becoming exhausted or insufficient. The Company shall be at liberty at any time and from time to time to appropriate and apply any security so deposited as aforesaid in or towards payment or satisfaction of all or any moneys which shall become due or owing by the consumer to the Company in respect of the supply of energy or otherwise under this Agreement but the provisions in this clause contained shall not prejudice any other remedy to which the Company may be entitled for the recovery of such moneys. The Company shall pay to the consumer interest at the rate of 5 per cent per annum on every sum of Rs. 10 or over comprised in such security for every complete period of twelve calendar months during which the same shall remain on deposit with the Company, and the said premises shall be connected with the Company's distributing main.

9. The consumer shall not be at liberty save with the consent of the Company to determine this Agreement before the expiration of   from the date of commencement of the supply of electrical energy hereunder. The consumer may determine this Agreement at any time after the said period on giving to the Company not less than one calendar month's notice in writing in that behalf and upon the expiration of the period of such notice this Agreement shall cease and determine without prejudice to any right which may then have accrued to the Company hereunder.

Provided always that the consumer may at any time with the previous consent of the Company transfer this Agreement to any other person and upon subscription by such transferee of these presents this Agreement shall become binding on the transferee and the Company, and take effect in all respects as if the transferee had originally been party hereto in place of the consumer, who shall thenceforth be discharged from all liability under or in respect hereof.

10. This Agreement shall be read and construed as subject in all respects to the provisions of the Bellary Electric Licence, 1921 and to the provisions of the Indian Electricity Act, 1910, and of any modification or re-enactment thereof for the time being in force and the rules for the time being in force thereunder so far as the same respectively may be applicable. The supply of electrical energy under this Agreement is subject to the following among other provisions of law, namely :—

(1) The Company shall be entitled to discontinue such supply—

(a) if the consumer has not already given security, or if any security given by him has become invalid or insufficient, and such consumer fails to furnish security or to make up the original security to a sufficient amount, as the ~~scae~~ case may be, within seven days after the service upon him of notice from the Company requiring him so to do, or

(b) If the consumer fails to pay the amount of any bill due under this Agreement within 15 days from the date thereof he shall pay interest on the said amount at the rate of 12 per cent. per annum from the expiration of such fifteen days until payment. If the amount of such bill remains unpaid, the Company may give the Consumer seven days' notice of their intention to discontinue the supply of energy, and at the expiry of such period, if payment has not been received, may forthwith disconnect the supply, until such sum and any expenses incurred in cutting off and reconnecting the supply are paid, or

(c) ~~(b)~~ if the consumer adopts any appliance, or uses the energy supplied to him by the Company for any purposes, or deals with it in any manner, so as unduly or improperly to interfere with the efficient supply of energy to any other person by the Company, or

(*c*) if the electric wires, fittings, works and apparatus of the consumer are not in good order and condition, and are consequently likely to affect injuriously the use of energy by the Company, or by other persons, or

(*d*) if the consumer makes any alterations of, or addition to, any electric wires, fittings, works and apparatus within his premises as aforesaid, and does not notify the same to the Company before the same are connected to the source of supply, with a view to their being examined and tested.

(2) Where the consumer has required the Company to supply him at a specified maximum rate, he shall not be entitled to alter that maximum, except after one month's notice in writing to the Company, and the Company may recover from the consumer any expenses incrurred by them by reason of such alteration in respect of the service-lines by which energy is supplied to the consumer beyond one hundred feet from the Company's distributing main, or in respect of any fittings or apparatus of the Company upon that property.

(3) Where any difference or dispute arises as to the amount of energy to be taken or guaranteed, or as to the cost of any service-line or as to the sufficiency of the security offered by any consumer or as to the improper use of energy, or as to any alleged defect in any wires, fittings, works or apparatus, the matter shall be referred to an Electric Inspector and decided by him.

(4) Rule 23. (1) The Company shall not connect the wires and fittings on a consumer's premises with his works unless he is reasonably satisfied that the connexion will not, at the time of making the connexion, cause a eakage from those wires and fittings exceeding one ive-thousandth part of the maximum supply demanded n the consumer's premises.

(2) Where the Company declines to make a connexion, in accordance with sub-rule (1) they shall serve upon the consumer a notice stating the reasons for so declining.

(5) Rule 24. (1) If at any time the Company has reason to believe that a leakage likely injuriously to affect the use of energy by the Company or by other persons exists in the premises of a consumer then the Company may give the consumer reasonable notice in writing, that they desire to inspect and test such wires and fittings belonging to the consumer as form part of the circuit.

(2) If the consumer does not give all reasonable facilities for inspection and testing, or if a leakage from the consumer's wires exceeding one five-thousandth part of the maximum supply demanded on the premises is discovered, the Company may forthwith discontinue the supply of energy to the premises in question, giving immediate notice of the discontinuance to the consumer, and need not recommence the supply until the cause of the leakage has been removed.

(6) Rule 25. (1) Where a consumer is dissatisfied with the action of the Company under rule 23 or rule 24 in refusing or discontinuing, or in not recommencing, the supply of energy to his premises, the wires and fittings of such consumer shall, on his application and on the payment of the prescribed fee, be tested for the existence of leakage by an Electric Inspector or other officer appointed to assist an Electric Inspector.

(2) If the Electric Inspector or other officer as aforesaid on testing finds that the leakage from the consumer's wires is less than one five-thousandth part of maximum supply demanded on the premises, the Electric Inspector shall notify the Company and the Company shall within twenty-four hours commence or continue the supply of energy.

THE SCHEDULE ABOVE REFERRED TO.

(1) Description of the premises at which the supply is to be given.

(2) Purposes for which the supply is to be given, and in the case of domestic supply under which rate to be charged, as referred to in paragraph 5.

(*a*) (Supply)

(*b*) (Rate)

(3) Maximum electrical power required by the consumer.

(4) Minimum consumption guaranteed by consumer

AS WITNESS the hands of the parties the day and year first above written.

The Bellary Electric Supply Co., Ltd.,

Witness.

Managing Director.

Witness. *Signature of Consumer.*

Hoe & Co., Madras.

P.W.D

Bellary Electric Licence 1921.
Conditions, Rates and General Information
for the Supply of electric energy.
C.No: 675 Rd. from the Bellary Electric Supply Coy Ld Ref no: 53/4 d 17-2-25

U.S.

Submitted.

The booklets may be sent to E.I.G.M. [illegible] if they are in order

Rec. No. 675
3 [illegible]

[illegible] 25

Alm
27/2

Rd No 919
20.4.25

The three booklets contained many minor inaccuracies & omissions; I return those booklets duly corrected in red ink & brought into line almost with the G. booklets approved for British Cochin & Madras Elec Supply Corpn; two booklets may be sent back for the submission of ten copies for final approval.

E J B Greenwood
20.4.25

P.W.D

US

The booklet for the Cochin Electric License was approved in G.O. No 528 W d 24-4-1925 & that of the Madras Electric Supply Corporation is under separate consideration. The booklet of

2

booklet of the Bellary Electric Supply Company may first be sent to the Municipal Council, Bellary first remarks vide ~~under~~ Section 21(2) of the Indian Electricity Act. A draft memo is submitted which may be issued and then sent for ~~after~~ perusal ~~by~~ to the L.S.G. dept.

After the file is recd back from LSG, the booklet will be read

7.5.25

8/5

11/5/25

L. S. G.

Issued
as P 675 A-3 P.W. 4-5 (
13.5.25)

I.D.
R.D. 2 weeks

6/5/25
(1) Issue
(2) L.S.G. (w.o)

L. S. G.

with 3 copies of booklets put up.

May be perused and the file returned to P.W.D. u.o.

P.W.D. No. 675 A/25-4
18.5.25

21.5.25
22/5

P.W.D.

20 MAY 1925

For Secy

P.W.D.

D.P.
23/5

11220-1, L
23.5.25

SECRETARY TO GOVERNMENT
285 Gl.
26 MAY 1925
PUBLIC

The booklet of the Bellary Electric Supply Co. has been compared with that relating to ~~the~~ Cochin Electric Licensee + the model# form and the following variations are noticed.

copy [illegible]

(1) Part I. Condition 6 (b) of the Cochin booklet is not found in the Bellary booklet

(2) The foot note on p 1 of the Bellary booklet is omitted in the case of Cochin.

(3) The foot note on p 5 of the Bellary booklet is not found in the Cochin booklet ~~or in the model form~~. This is however a mere reference to rules.

(4) Part I condition 13. Portion side lined in pencil in the Bellary booklet is not in the Cochin booklet but is found in the model form

(5) Part I. Condition. 17. There is no condition ~~corresponding~~ in the Bellary booklet corresponding to condition 17 (1) in the Cochin booklet..

(6) Parts II & III in the two booklets vary

(7) Appendix C. In Rule no 62 para 3 (a) - the following words are omitted "or to make in or upon any building or structure any permanent or temporary." after the words permanent or temporary in lines 3 & 4 - The omission ~~should be~~ may be rectified.

(8) Appendix E. Clause 9. The proviso in the Bellary booklet is not found in the other booklet but is in the model form.

(9) Appendix E. Clause 10 (1) (b) in the Bellary booklet is a new addition. It is not found either in the model form or in the Cochin booklet.

(10) Appendix E Clause 10 (1) (a), (b) (c) (d) ~~(e)~~ ~~[illegible]~~ for the words " owner or occupier of

of the property to which the supply is made" used in the Cochin booklet the word "consumer" is adopted in the Bellary booklet.

2 One copy of the booklet has been sent to the Chairman Municipal Council Bellary for obtaining of the Council's remarks. – vide memo no 675 A1/25-3 of 15-5-25 & his reply is awaited. In the meantime the file may be sent to the Electrical Inspector no. and he may be requested to state whether any alterations or additions are necessary in the Bellary booklet with reference to the ~~points~~ remarks ~~observations~~ made in para 1 above.

ACS 5/6/25 The modifications in the appd Cochin license, as compared with the model form were made at the instance of the El. Inspr

ACS 8/6

9.6.25

To E.I. ro.
(By [illegible])

Office of the Electrical Inspector
Recd No 1640
12 JUN 1925

ID

PW Dno 285 Jl-1
11-6-25
(Prefe
E.I.G. U.O.No-1335
13-6-25.
9/6

The following remarks are offered on the points raised in para 1 above –

(1). Sub-para (1) at foot of page 2 – Condition 6(b) – relating to wiring of Consumer's premises – of the

Cochin booklet was specially framed for by the Cochin licensees whilst the Bellary licensees preferred to follow the Model Form. No change is therefore necessary.

(2). Sub-paras (2)* and (3) on page 3 - The foot notes were taken from the Model Form; they serve as mere references to rules and although not essential in a booklet of conditions may still ~~be retain~~ remain in the Bellary booklet.

(3). Sub-para (4) - Condition 13 of the Bellary booklet is exactly the same as in the model form & may be retained as it stands. The licensees for Cochin aimed at fixing up the agreement before giving a supply & so omitted the portion side-lined in pencil from their booklet.

(4). Sub-para (5) - The system of supply in Cochin is A.C. whilst in Bellary D.C. supply is given. Hence the difference in Condition 17(1) of the two booklets. No change is needed in the Bellary book.

(5). Sub-para (6) - The rates given under Parts II and III of the two booklets are not in excess of the normal rates and there is no other material difference between the two. There is therefore no objection to the acceptance by Govt of parts II and III in the Bellary booklet.

A (6). Sub-para (7) - The omission of rule 62(3)(a) under Appendix C in the Bellary booklet may be justified.

(7). Sub-para (8) - The proviso to clause 9 in

Appendix E of the Bellary Booklet was based on the Model Form and may be retained. The licensees for Cochin did not wish to leave it in their booklet & so the proviso was not provided for therein.

(8). Sub-para (9)_Clause 10(1)(b) of Appendix E to the Bellary booklet was specially provided for at the instance of the licensees & may therefore be accepted.

(9). Sub-para (10) – Throughout clause 10 of Appendix E. to the Bellary booklet, the term "Consumer" was ~~[illegible]~~ adopted in place of "owner or occupier of the property to which the supply is made" used in the Cochin booklet; the former is a more appropriate term and may therefore remain in the Bellary booklet. It is suggested that this term is adopted in all future booklets coming to Govt for approval & also in the model form already approved by Govt.

B

Amendment issued in form 1144W / 3-8-25

13/6/25

SECRETARY TO GOVERNMENT
1192 GL
16 JUN 1925
PUBLIC WORKS DEPAR

13/6/25

The only amendment to be made in the Bellary booklet is that mentioned at A on p 5 ante. This has been done

2 ~~Action~~ With reference to B above action to amend# the model form will be taken when final orders are issued on this case.

amendment issued in form 1144W 3/8/25 (N)

3 The Chairman's reply to memo no.

Memo no 6,13 R.D/25-3 of 15.5.25 has not yet been received. A draft reminder is submitted.

am
18/6/25

RVS
18.6.25

p 6 cp Issued as Memo no 285 Gl-2 of 18.6.25 /

pp 12·13 CU from the Chairman M.C. Bellary No. ~~Ref. S. CR 10~~ of 8.9.25

~~[illegible]~~

Supr

2 A draft memo ~~to the~~ asking the licensees to supply 10 copies of the pamphlet as amended by Govt – vide El. Insp'r's note on p 1 ante – is put up.

am
16 9 25

The Bellary Municipal Council have no objection to the pamphlet being approved. It is unnecessary to consult the Govt Solicitor about the pamphlet as it is based on a model form app'd by Govt.

RVS
16.9.25

am
16/9

Secy

DR2 [illegible]
19/9

Memo no. 285 Gl-5 of 21-9-25

C no 229 B/26 from the Bellary El. Supply Corporation Ltd dated 8.1.26.

Secy

The El Inspector to Govt has reported

8/

Separately that the Bellary El. License Concern is likely to be wound up. Nothing further is known of the El Insp. has been asked to report on this point in another connection. It does not seem necessary to defer approval to the 'conditions rates etc' pending receipt of the information called for. A draft order is submitted.

11/1/26 11.1.26

Issued
11.1.26

Sectt.-II-5(a)—28,703—6-12-24. (6)

8

PW. DEPARTMENT.

	Date.	Initials.
When received for Fair-copying.		
When copied	AV	12/1/26
When examined		
When signed	12/1	U
When despatched		

Electricity. – The Bellary Electric Licence, 1921 – ~~[illegible]~~ Conditions, rates, etc. for the supply of electric energy – Approved

READ AGAIN G.O. No. 931 W, dated 5-7-1921.

" " " " 815 W " 16-8-1923.

(not printed)

READ ALSO:—

C. No. From the , No. , dated , 192 .

" " 2291 from The Bellary El. Supply ~~Corporation~~ Company Ltd. dated 6-1-1926

p 17 cf

" " " " " " 192

ORDER.

No. 57 W, dated 12-1-1926.

Ms.

The conditions, rates and general information for the supply of electric energy submitted for the approval of Govt. under section 21(2) of the Indian Electricity Act by the Bellary El. Supply ~~Corporation~~ Company Ltd., Bellary, – the licensees under the Bellary Electric Licence, 1921 – are approved.

(By order)

AM
11.1.26

11.1.26.

Secy

15 [illegible]

To the Bellary El. Supply Corporation Ltd., Bellary.

" Chairman, M.C., Bellary
" El. Inspector to Govt. } with a copy of the pamphlet "Conditions, rates etc. for the supply of electric energy")
" L.S. Dy

Copy for section